



City of Anaheim
PURCHASING DIVISION

August 28, 2008

ADDENDUM #1

BID # 7162-FURNISH & INSTALL: CONTROLLERS: AIR AND FUEL RATIO

The following addendum is issued to clarify the following.


1. QUESTION: What is the status of the existing catalysts?
ANSWER: requested information not available or not pertinent to this bid.
2. When were the catalysts installed?
ANSWER: requested information not available or not pertinent to this bid.
3. Who was the catalyst manufacturer?
ANSWER: see table below.
4. What size of catalysts?
ANSWER: requested information not available or not pertinent to this bid.
5. How often are the catalysts maintained?
ANSWER: requested information not available or not pertinent to this bid.
6. What are the estimated total hours of operation?
ANSWER: see table below.
7. Are the engines prime engines, or emergency?
ANSWER: all three engines are emergency engines.
8. If the catalysts are several years, they may not pass the AQMD emissions limit. Would the city be OK, with replacing the catalysts if it fails the emissions test?
ANSWER: yes, a line has been added to the PRICE SHEET for each unit, in the event that the unit requires replacement of its catalytic converter.
9. Which AFRC are you currently running?
ANSWER: see table below.

Additionally, various photos of unit have been attached for review.


You must also acknowledge, on the line provided under point #19 of the Vendor's Bid Package, all addendum that you have received wherein it states:

To ensure that your bid is predicated upon having received all such addendum, enter the last number received below; if none have been received, enter "none":

There are no other changes, additions, or deletions by issuance of this addendum.



NEIL GROOM
Buyer II
714-765-5207 T
714-765-5288 F
ngroom@anaheim.net


DATE

200 S. Anaheim Boulevard
Purchasing, Suite 620
Anaheim, California 92805-3820

TEL (714) 765-5110
FAX: (714) 765-5288

e-mail: purchasing@anaheim.net

#994: MFG: WAUKESHA F 18 G
DATE: 1990
DESCRIPTION: HOUSTON INDUSTRIAL SILENCING AUTOMATIC AIR FUEL
RATION CONTROLLER
MODEL #: 88EM-A-1

CATALYTIC CONVERTER: HOUSTON INDUSTRIAL SILENCING / De NOx SILENCER
MODEL #: DN / S-2406H
DATE MFG.: 6-1-89
DWG #: PC-995 E
DIMENSIONS: L 96" X DIA 18" / INLET AND OUTLET 6" ASA FLANGES
HOURS OF OPERATION: 687
GASEOUS EMISSIONS: NO CURRENT STATE CERTIFIED TESTS

#956: MFG: CATERPILLAR 3412 SI
DATE: 1993
DESCRIPTION: HOUSTON INDUSTRIAL SILENCING AUTOMATIC AIR FUEL
RATION CONTROLLER
MODEL #: 88EM-A-1

CATALYTIC CONVERTER: HOUSTON INDUSTRIAL SILENCING / SILENCER / CATALYTIC
CONVERTER, CRITICAL HOSPITAL GRADE WITH 10" ASA INLET
AND OUTLET FLANGES
MODEL#: not available
DWG #: not available
DIMENSIONS: L 10' X DIA 30" / 3 SECTIONS, 2 OUTER SECTIONS 4' AND
CENTER SECTION 2'.
HOURS OF OPERATION: 304
GASEOUS EMISSIONS: NO CURRENT STATE CERTIFIED TESTS

#958: MFG: WAUKESHA F 2895 GL
DATE: 1992
DESCRIPTION: HOUSTON INDUSTRIAL SILENCING AUTOMATIC AIR FUEL
RATIO CONTROLLER
MODEL #: 88EM-A-1

CATALYTIC CONVERTER: HOUSTON INDUSTRIAL SILENCING De NOx SILENCER
MODEL#: not available
DWG #: not available
DIMENSIONS: L 153" X DIA. 30" WITH INLET AND OUTLET 10" ASA FLANGES.
SILENCER IS IN 2 SECTIONS: INLET 64" LONG / OUTLET
SECTION 89" LONG.
HOURS OF OPERATION: 286
GASEOUS EMISSIONS: NO CURRENT STATE CERTIFIED TESTS

REVISED: 08-28-08

PRICE SHEET: OPTIONAL: FURNISH & INSTALL: CATALYTIC CONVERTERS				
LN	QTY	UN	DESCRIPTION	EXT. PRICE
1	1	LOT	FURNISH & INSTALL CATALYTIC CONVERTER: WALNUT CANYON	\$
2	1	LOT	FURNISH & INSTALL CATALYTIC CONVERTER: CANYON VISTA	\$
3	1	LOT	FURNISH & INSTALL CATALYTIC CONVERTER: NOHL CANYON	\$

There will be a **OPTIONAL JOBWALK** on **THURSDAY, AUGUST 21, 2008 at 10:00 A.M.**
Location is **6751 E. WALNUT CANYON, ANAHEIM, CA 92805.**

**ALL BIDS ARE TO BE SUBMITTED ORIGINAL AND ONE COPY **

DELIVERY REQUIRED: PER BID SPECIFICATIONS AFTER AUTHORIZATION TO PROCEED.

STANDARD TERMS: NET 30 DAYS - ENTER DISCOUNT TERMS IF APPLICABLE _____

FOB: PER BID SPECIFICATIONS

NOTE: Bidder to enter applicable and current sales tax rate, however, the City will agree to pay applicable and current sales tax in effect at time of shipment.

Continue to bid instructions and other applicable forms

