



City of Anaheim
PURCHASING DIVISION

November 17, 2009

ADDENDUM #1

**BID # 7330 – ADVANCED METERING INFRASTRUCTURE (AMI)
WATER METERS**

This addendum is issued to provide answers to bidder's questions below.

Question #1:

Will this bid be awarded by overall total or by line item?

City Response:

Bid will be awarded to one vendor.

Question #2:

Are all the large quantity items to be supplied with Orion MIU unit, or just where specified?

City Response:

All meters shall be AMI type meters. Therefore, all meters shall be supplied with all required components to communicate with the City's fixed radio network through the special Orion transmitter.

Question #3:


Are all meters to be supplied with encoder register, or are some of them direct read? Are all meters to be supplied with Orion transmitter, or just where stated in the product schedule?

City Response:

All meters shall be supplied with an encoder register and the Orion transmitter.

There are no other changes, additions or deletions by issuance of this addendum.


VALERIE HANDZUS, BUYER II


Date

200 S. Anaheim Boulevard
Purchasing, Suite 620
Anaheim, California 92805-3820

TEL (714) 765-5110
FAX: (714) 765-5288

e-mail: purchasing@anaheim.net