



City of Anaheim
PURCHASING DIVISION

February 2, 2010

ADDENDUM #1

BID # 7358 – ADVANCED METERING INFRASTRUCTURE (AMI) WATER METERS

This addendum is issued to provide answers to bidder's questions below:

Question #1:

Bottom plates – as we have the rubber liner, do these still need to be LL?

Response:

Yes. Per bid specification Section 2.h. on Page 3 of 12, bottom plates shall be LL material (same as main case).

Question #2:


Strainers – “All meters must be provided with a corrosion resistant strainer, which is easily removable from the meter” – Do they want external strainers on the compounds?

Response:

Yes. Compound meters shall be provided with external strainers.

There are no other changes, additions or deletions by issuance of this addendum.


VALERIE HANDZUS, BUYER II


Date

200 S. Anaheim Boulevard
Purchasing, Suite 620
Anaheim, California 92805-3820

TEL (714) 765-5110
FAX: (714) 765-5288

e-mail: purchasing@anaheim.net