

CITY OF ANAHEIM
PUBLIC UTILITIES DEPARTMENT
Water Engineering Division

DATE: February 13, 2013
TO: Future Water Customer/Applicant
FROM: Water Engineering Division

SUBJECT: Required Backflow Prevention Devices for Proposed Firelines

Please answer the following questions to determine if a reduced pressure principle detector check backflow prevention device will be required for your proposed fireline:

1. Does the private fire protection system include any on-site auxiliary or supplemental water supply sources, such as tanks, reservoirs, or pumps? Yes No

2. Will the fire protection system include the addition of any chemicals or foaming agents? Yes No

A **reduced pressure principle detector check** backflow protection device may be required if any questions above have a "Yes" response. Otherwise, if all the responses are "No", a **double detector check backflow** prevention device will be acceptable. Please contact a Fire Safety Specialist of the Anaheim Fire Department to confirm that the private fire protection system is consistent with the responses provided above. ****In the event the answers you provide on this form later change, then you may be required to change the type of backflow prevention device on your service line.****

All water service connections for domestic and irrigation purposes, except for single-family residences, will require a reduced pressure principle backflow prevention device.

Please provide the following information and return this questionnaire with your initial plan check submittal.

(Project Location / Address)

(Applicant's Name)

(Company)

(Address, if different than above)

(City, State, Zip)

(Phone) (FAX)

(Applicant's Signature)

If you have any questions, please contact Water Engineering at (714) 765-5196.