

# TEST RESULTS

January 2020

<b>Groundwater well</b>	<b>PFOA</b>	<b>PFOS</b>	<b>PFOA and PFOS</b>
Well 39	6.9	12.5	19.4
Well 40	12.9	27.5	40.4
Well 42	17.8	39.6	57.4
Well 44	12.9	31.4	44.3
Well 45	13.8	27.7	41.5
Well 46	25.8	62.8	88.6
Well 47	9.6	21.5	31.1
Well 48	6.0	15.6	21.6
Well 49	11.8	30.2	42
Well 51	2.7	5.6	8.3
Well 52	18.3	46	64.3
Well 53	5.7	15.2	20.9
Well 54	17.3	49.1	66.4
Well 55	24.2	51.4	75.6
Well 56	16.1	48.4	64.5
Well 58	18.3	45.5	63.8
Well 59	14.8	31.3	46.1
Linda Vista	17.8	41.3	59.1

Measurements in nanograms per liter, equivalent to parts per trillion.

While the majority of PFOA, PFOS or combined levels above require local notification to local officials, they are *below* federal and state limits for drinking water use.

Wells with concentrations below California's response level remain in service with close monitoring and testing. Should levels in any given well rise to the state's response level, Anaheim Public Utilities will take action.

Wells above that have combined PFOA and PFOS levels above the California's response level have been taken offline in the abundance of caution, and other water sources are being used to serve customers.