



City of Anaheim  
DEPARTMENT OF PUBLIC WORKS

**ADDENDUM NO. 1**

TO THE BID DOCUMENTS FOR

**CENTER GREENS IMPROVEMENTS**

Account Nos. 460.410.5702.9601.CTRGREENS; 216.213.4765.9601  
GRA2021-03737, BLD2021-05508; SGN2022-00005; WQMP2021-01411

November 15, 2022

---

I. GENERAL

The following changes, additions, or deletions shall be made as indicated, and all other conditions shall remain the same.

II. CONTRACTOR QUESTIONS & ANSWERS

---

Q1 Is this project subject to a PLA (Project Labor Agreement), a PSA (Project Stabilization Agreement), a CBA (Collective Bargaining Agreement), a CWA (Community Workforce Agreement), or anything of that nature?

A1 **Yes. This project is subject to the City's Community Workforce Agreement (CWA) as indicated on PlanetBids under Description and Scope and in the bid documents. Additional details regarding the awarded Contractor's compliance with the CWA will be provided at the Mandatory Pre-Bid Meeting.**

---

Q2 SpectraTurf would like to submit our SpectraPour Supreme product for review to be an approved equal product for the Rubberized Safety Surfacing on the Challenge Course per specification section 321816-2.1.A.

A2 **This is an acceptable substitution.**


---

Q3 SpectraSystems would like to submit our SpectraTurf – SpectraPour Supreme Standard Curb – Flush to Concrete Curb or Wall submittal for approval for the resilient safety surfacing per manufacturer and IPEMA/ASTM tested. Please note when additional wear layer material is thickened on the edge it is more dense and does not attenuate the same as the surrounding safety surfacing. In this case the perimeter edge with the thickened edge does not meet a majority of the ASTM requirements notated within the specification section 321816. The cost per lineal foot is also increased upwards of +\$30.00 per lineal foot and there is no IPEMA Testing from any manufacturer for a thickened edge system as shown in detail 4. Customer will assume all liability for edge or seam failures and compliance for thickened edge detail shown not by manufacturer. Please note that Detail 4 states "color wear layer per manufacturer" and "cushion layer, per manufacturer." Reference Sheet LC-2.0, Detail 4. Reference Specification Section 321816-3.1.A. "Comply with the instructions and recommendations of the playground surfacing manufacturer."

A3 **The attenuation concerns are only applicable if located within the fall zone. This edge condition is located outside of the fall zone; therefore, is not required to comply with fall zone attenuation requirements.**

- 
- Q4 SpectraSystems would like to submit our SpectraTurf – SpectraPour Supreme Bevel Cut for Wear Layer for approval for the resilient safety surfacing. Reference Sheet LC-2.0, Detail 5. Please note detail states “wear layer color #1 per manufacturer” and “wear layer color #2 per manufacturer”. Reference specification section 321816, 3.1-A. “comply with the instructions and recommendations of the playground surfacing manufacturer.”
- A4 **The phrase ‘per manufacturer’ will be removed from the detail and specs. Contractor shall bid and install as indicated in details and specifications. The updated detail and spec will not give contractor independent authority for use of alternate installation details.**
- 

Sincerely,



Brenda Medina  
Construction Contract Administrator

cc Raul Garcia Ana Straabe  
Naomi Gruenthal File

---

The Contractor shall acknowledge receipt of all addenda by signing and enclosing each addendum form in its bid submittal. Failure to do so may result in a rejection of bid.

---

Signature

---

Print Name

---

Firm Name

---

Date