


**SCOPE: THIS STANDARD SHOWS TYPICAL SPACING FOR SPECIFIED STREETLIGHT DESIGN.**

**LOCAL**

STREET WIDTH	36'	52'
MOUNTING HEIGHT	31'-6"	31'-6"
SPACING STAGGERED 100W	190	160

**COLLECTOR/SECONDARY**

STREET WIDTH	44'	70'
MOUNTING HEIGHT	31'-6"	31'-6"
SPACING STAGGERED 200W	250*	205



**STAGGERED SPACING**

**MAJOR/ PRIMARY**

STREET WIDTH	100'
MOUNTING HEIGHT	31'-6"
SPACING STAGGERED 200W	125

**DESIGN 736**

FILENAME: L136A REV 0

**CITY OF ANAHEIM**  
PUBLIC UTILITIES DEPARTMENT  
ELECTRICAL DIVISION  
T&D CONSTRUCTION STANDARDS

REVISION KEYS:



ADDED / REVISED TEXT



ADDED / REVISED MATERIAL

NEW SHEET

REVISION NO. **0**  
ISSUE DATE: **01-13**  
SHEET **1** OF **4**  
CONSTRUCTION STANDARD:

**STREET LIGHT SPACING**

**L 136A**

APPROVALS

PREP BY	T&D MGR	SYS PLN MGR	OPS MGR	SUB MAINT
MH	EB	-	SM	-


**SCOPE: THIS STANDARD SHOWS TYPICAL SPACING FOR SPECIFIED STREETLIGHT DESIGN.**

**LOCAL**

ST. WIDTH	36'	52'
MTG. HGT.	24'	24'
SPACING STGRD 100W	165	120

**COLLECTOR/ SECONDARY**

ST. WIDTH	44'	70'
MTG. HGT.	24'	24'
SPACING STGRD 100W	105	70



**STAGGERED SPACING**

**DESIGN 738**

**LOCAL**

ST. WIDTH	36'	52'
MTG. HGT.	24'	24'
SPACING STGRD 100W	215	160

**COLLECTOR/ SECONDARY**

ST. WIDTH	44'	70'
MTG. HGT.	24'	24'
SPACING STGRD 100W	135	95

**DESIGN 739**

FILENAME: L136A REV 0

**CITY OF ANAHEIM**  
PUBLIC UTILITIES DEPARTMENT  
ELECTRICAL DIVISION  
T&D CONSTRUCTION STANDARDS

REVISION KEYS:



ADDED / REVISED TEXT



ADDED / REVISED MATERIAL

NEW SHEET

**STREET LIGHT SPACING**

REVISION NO. **0**  
ISSUE DATE: **01-13**  
SHEET **2** OF **4**  
CONSTRUCTION STANDARD:

**L 136A**

APPROVALS

PREP BY	T&D MGR	SYS PLN MGR	OPS MGR	SUB MAINT
MH	EB	-	SM	-

**SCOPE: THIS STANDARD SHOWS TYPICAL SPACING FOR SPECIFIED STREETLIGHT DESIGN.**


**LOCAL**

ST. WIDTH	36'	52'
MTG. HGT.	14'-10"	14'-10"
SPACING STGRD 100W	45	30

**COLLECTOR/ SECONDARY**

ST. WIDTH	44' NO PARKING
MTG. HGT.	14'-10"
SPACING STGRD 100W	20

**DESIGN 742**



**STAGGERED SPACING**

**LOCAL**

ST. WIDTH	36'	52'
MTG. HGT.	15'-4"	15'-4"
SPACING STGRD 100W	45	35

**COLLECTOR/ SECONDARY**

ST. WIDTH	44'
MTG. HGT.	15'-4"
SPACING STGRD 100W	25

**DESIGN 743**

FILENAME: L136A REV 0

**CITY OF ANAHEIM**  
PUBLIC UTILITIES DEPARTMENT  
ELECTRICAL DIVISION  
T&D CONSTRUCTION STANDARDS

REVISION KEYS:



ADDED / REVISED TEXT



ADDED / REVISED MATERIAL

NEW SHEET

**STREET LIGHT SPACING**

REVISION NO. **0**  
ISSUE DATE : **01-13**  
SHEET **3** OF **4**  
CONSTRUCTION STANDARD:

**L 136A**

APPROVALS

PREP BY	T&D MGR	SYS PLN MGR	OPS MGR	SUB MAINT
MH	EB	-	SM	-


**SCOPE: THIS STANDARD SHOWS TYPICAL SPACING FOR SPECIFIED STREETLIGHT DESIGN.**

**LOCAL**

ST. WIDTH	36'	52'
MTG. HGT.	29'-4"	29'-4"
SPACING STGRD 100W	195	160

**COLLECTOR/SECONDARY**

ST. WIDTH	44'	70'
MTG. HGT.	29'-4"	29'-4"
SPACING STGRD 200W	250 *	195



**STAGGERED SPACING**

**DESIGN 744, 746, 747, 749, 750  
ALL SINGLE ARM**

**MAJOR /PRIMARY**

ST. WIDTH	100'
MTG. HGT.	29'-4"
SPACING STRGD 200w	120

**DESIGN 744 & 745  
SINGLE & DOUBLE ARM COMBINATION**

\* NOT MAX SPACING

FILENAME: L136A REV 0

<b>CITY OF ANAHEIM</b> PUBLIC UTILITIES DEPARTMENT ELECTRICAL DIVISION T&D CONSTRUCTION STANDARDS	REVISION KEYS:  ADDED / REVISED TEXT  ADDED / REVISED MATERIAL  NEW SHEET	REVISION NO. <b>0</b>
	<b>STREET LIGHT SPACING</b>	ISSUE DATE: <b>01-13</b>
		SHEET <b>4</b> OF <b>4</b>
		CONSTRUCTION STANDARD: <b>L 136A</b>
APPROVALS		
PREP BY: <b>MH</b>	T&D MGR: <b>EB</b>	SYS PLN MGR: <b>SMK</b>
OPS MGR: <b>SMK</b>	SUB MAINT: <b>-</b>	