



**NOTE C**  
CEILING HEIGHT MINIMUMS  
 STANDARD LEVELS 7' 0"  
 ACCESS LEVELS TO HANDICAP PARKING 8' 2"  
 \*\* NO INTRUSION OF UTILITIES OR FIXTURES PERMITTED WITHIN CLEARANCE HEIGHT REQUIREMENTS

**NOTE B**  
RAMP SECTION REQUIREMENTS  
 MINIMUM LENGTH OF RAMP TRANSITION IS 12' BTWN. GRADE BRKS.  
 MAXIMUM GRADE BREAK IS 5%  
 15% RAMP GRADE  
 MAXIMUM NO PARKING  
 5% RAMP GRADE  
 MAXIMUM WITH PARKING

**NOTE A**  
INITIAL SECTION REQUIREMENTS

USE	MINIMUM LENGTHS	MAXIMUM GRADE
RESIDENTIAL	20'	5%
COMMERCIAL	40'	5%
INDUSTRIAL	60'	5%

GATE STANDARDS  
(IF INSTALLED)

NUMBER OF PARKING SPACES	MINIMUM SET BACK FROM RIGHT-OF-WAY
1-60	40'
61-120	60'
121 +	100'
INDUSTRIAL USE	60'

TURN-AROUND AREA REQUIRED  
 EXEMPTION REQUIRES TRAFFIC ENGINEER'S AUTHORIZATION.

GENERAL NOTES

THIS STANDARD APPLIES TO BOTH COVERED AND UNCOVERED FACILITIES.  
 ALL PARKING LAY-OUT SHALL CONFORM TO CITY OF ANAHEIM STANDARD DETAILS NOS. 601 & 602.  
 HELICAL RAMPS SHALL HAVE A MINIMUM OUTER RADIUS 35'.  
 CONSIDERATION MUST BE GIVEN TO PEDESTRIAN MOVEMENTS AT PARKING LEVELS.

APPROVED	6-86
REVISION	7-85

**CITY OF ANAHEIM**  
 DEPARTMENT OF PUBLIC WORKS  
 ENGINEERING DIVISION

APP *Ray E. Johnson* 7/31/85  
 CITY ENGINEER DATE

PARKING STRUCTURE & RAMP  
 STANDARD DETAIL

APP *Will G.* 6-20-85  
 TRAFFIC ENGINEER DATE

STD. PLAN NO. 402-B